## CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

## **Inspection Summary**

Permit #:PRRES20181488, Building Permit - Residential Address: 4060 NE CHAPEL MANOR DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

**Gas Service Inspection -** John Borns Failed Tuesday, November 06, 2018

Residential

Corrective Action Required

1 Misc LSCO 7-608: GAS PIPING PRESSURE TEST BELOW LEE'S SUMMIT

10 PSI REQUIRED MINIMUM.

Comments: PRESSURE JUST ABOVE 5 PSI.