

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20180854, Building Permit - Residential
Address: 4720 NE GATEWAY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	John Borns	Failed	Tuesday, November 06, 2018

Corrective Action Required

1	Misc	-As graded plot plan required to be submitted for verification. There are some areas that do not slope properly. -Window glazing within 24" of the rear patio door must be safety tempered glazing. APPROVABLE SAFETY FILM IS OPTION. -Solid block between lapped joists above I beam
---	------	---

Comments: