

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20181846, Building Permit - Residential
Address: 1301 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mike Copeland	Failed	Tuesday, November 06, 2018

Corrective Action Required

1 Misc

FRAMING:

-Stud cut off at basement wet bar

**install 2x4 header underneath

-Solid block joist ends above basement I beam

(BEAM TO THE FRONT OF THE HOUSE AT UNFINISHED AREA)

**OK TO INSULATE

Comments: