

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20181846, Building Permit - Residential
Address: 1301 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Mike Copeland	Failed	Tuesday, November 06, 2018

Corrective Action Required

1	Misc	-REDO THE REBAR GROUNDING CONNECTION. THE GROUNDING ELECTRODE CONDUCTOR MUST BE WEDGED IN BETWEEN THE GROOVES OF THE GROUNDING CLAMP **LOCATE AND EXPOSE THE UFER CONNECTION. MUST BE ACCESSIBLE AT FINAL INSPECTION STILL NOT VISIBLE OR ACCESSABLE
---	------	--

Comments: