

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20181820, Building Permit - Residential
Address: 209 SW 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Residential	John Borns	Partial	Tuesday, November 06, 2018

Corrective Action Required

1	Misc	EXTERIOR GFCI RECEPTACLE AT SE NOT TRIPPING ON TEST.
		NO OTHER ISSUES FOUND.

Comments: