FileiPRCOM201730ZC

john borns

From: Sent: Cindi Pass [cindi.pass@yahoo.com] Friday, September 22, 2017 5:01 PM

To:

jborns@att.net

Subject:

Fwd: SS # 122310-LEE'S SUMMIT N. HIGH SCHOOL

Begin forwarded message:

From: Cindi Pass < cindi.pass@yahoo.com > Date: September 22, 2017 at 4:58:04 PM CDT

To: john.borns@cityofls.net

Subject: Fwd: SS # 122310-LEE'S SUMMIT N. HIGH SCHOOL

Begin forwarded message:

From: Dennis Jacobs < <u>DJacobs@siibrands.com</u>> **Date:** September 22, 2017 at 10:13:50 AM CDT

To: "cindi.pass@yahoo.com" <cindi.pass@yahoo.com>

Subject: FW: SS # 122310-LEE'S SUMMIT N. HIGH SCHOOL

Dennis Jacobs



Technical Director - Superior Shade Main: 770-832-6660 Direct: 678-390-1933

Cell: 770-833-9269 210 Industrial Court Carrollton, GA 30117

DJacobs@siibrands.com

www.superiorrecreationalproducts.com







ìn

This message and attachments are intended only for the designated recipient(s). They may contain confidential or proprietary information. If you are not a designated recipient, you may not review, copy or distribute this message and you are hereby notified that any dissemination of this communication is strictly prohibited. If you receive this in error, please notify the sender by reply e-mail and delete this message and any attachments. Thank you.

L



From: Soney FM LLC [mailto:soneyfmllc@yahoo.com]

Sent: Friday, September 22, 2017 10:42 AM

To: JHon.Borns@CityofLS.net

Cc: Dennis Jacobs < <u>DJacobs@siibrands.com</u>>

Subject: SS # 122310-LEE'S SUMMIT N. HIGH SCHOOL

HI: CONTRACTOR, JIM (PH: 417-235-9475) CALLED ME TO WHETHER EVALUATE FOR CORNER COLUMNS 4-#5 REBARS TOP AND BOTTOM WILL BE ADEQUATE. I DID EVALUATION AND FOUND IT TO BE ACCEPTABLE. IF ANY QUESTIONS, Please call or E-mail.

Dr. Ram Goel, Ph.D., P.E. Soney FM LLC 17863 Hunting Bow Circle, Suite 102 (SR 54) Lutz, FL 33558 Ph: 727-420-4796





in