

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20170812, Building Permit - Residential
Address: 1622 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Jason McRoy	Failed	Thursday, November 08, 2018

Corrective Action Required

- | | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">• Missing 3 joist hangers at deck• Self closing hinges at garage entry not operating properly• Label sub panel• Bag on smoke in furnace room• Closet light fixture is not mounted correctly |
| | | <ul style="list-style-type: none">• basement• Bag on smoke in bedroom in basement• Lockouts for oven and range• Provide as graded plot plan |

Comments: