

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200    FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20183477, Building Permit - Residential  
Address: 416 NW MAIN ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

|                                         |            |          |                             |
|-----------------------------------------|------------|----------|-----------------------------|
| Inspection:                             | Inspector: | Outcome: | Date:                       |
| <b>Footing Inspection - Residential</b> | John Borns | Passed   | Thursday, November 08, 2018 |

**Comments: OK TO POUR WHEN READY WALL FOOTINGS & ISOLATED FOOTINGS. UFER GROUNDING JUMPERS IN PLACE AT NORTH & SOUTH. ENSURE *MINIMUM 3" CLEARANCE FROM RE-BAR TO* BOTTOMS & BANKS.**