

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20183471, Building Permit - Residential
Address: 420 NW MAIN ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	John Borns	Passed	Thursday, November 08, 2018

Comments: OK TO POUR WHEN READY WALL FOOTINGS & ISOLATED FOOTINGS. UFER GROUNDING JUMPERS IN PLACE AT NORTH & SOUTH. ENSURE *MINIMUM 3" CLEARANCE FROM RE-BAR TO* BOTTOMS & BANKS.