

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200    FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20183409, Building Permit - Residential  
Address: 1320 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Residential</b>	John Borns	Passed	Friday, November 09, 2018

**Comments: CHECK RE-BAR AT JUMPS AND ENSURE  $\geq 3$ " CLEARANCE. ENSURE NO STANDING WATER AT TIME OF POUR. THEN OK TO POUR WHEN READY.**