

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20180476
Address: 1345 NE BRANDYWINE RD, LEES SUMMIT, MO 64064
Inspected On: Friday, November 09, 2018
Inspected By: John Borns
Expiration Date: 11/29/2018

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	John Borns	Temporary C of O	Friday, November 09, 2018

Corrective Action Required:

1	Misc	-FINAL GRADE, SOD, SPLASHBLOCKS -COMPLETE DECK -SEWER TRACE BOX AND WIRE SHALL BE ACCESSIBLE AT GRADE LEVEL -LOWER WATER METER SO THAT THE METER TOP-LID DISTANCE IS 14"-18"
---	------	---

DO NOT BURY DECK CEDAR POSTS