

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20181762, Building Permit - Residential
Address: 2508 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mark Harding	Failed	Monday, November 12, 2018

Corrective Action Required

1	Misc	-Firestop dbl wall at south bedroom from joist space and 10' horizontal. seal all penetrations. fire stopped with 1/2" not 3/4"
		-Brace lvl over breakfast room. brace the north end. -Fire stop dead space right of refrigerator. seal from attic

Comments: