

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200 FAX(816)969-1201

Inspection Summary

Permit #: PRRES20181586
Address: 1312 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mike Copeland	Failed	Tuesday, November 13, 2018

Corrective Action Required:
1 Misc

FRAMING:

- Nail garage portal wall sheathing at still and break in the sheathing.
- Solid Block garage cantilever.
- Seal around fireblocking/ penetrations in fireblocking in basement finish areas.

Okay to insulate

Comments: