

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200 FAX(816)969-1201

Inspection Summary

Permit #: PRCOM20183043
Address: 316 SE DOUGLAS ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Failed	Wednesday, November 14, 2018

Corrective Action Required:

1	Misc	DRAIN LINE DIRECTION AT RESTROOMS NOT PER APPROVED DRAWING.
2	Misc	LEAVE ALL NEW PIPING EXPOSED FOR INSPECTION -- INCLUDING CONNECTIONS TO EXISTING BUILDING DRAIN.

Comments: