

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200 FAX(816)969-1201

Inspection Summary

Permit #: PRSITE20180252
Address: 1600 SE HAMBLER RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer - Vacuum		Passed	Wednesday, November 14, 2018

Informational:

1 Misc

The crew vacuum tested the two public manholes.

The MH on the east side of Hamblen Rd. Is approximately 6'ft deep. The MH on the west side of Hamblen Rd. Is approximately 4'ft deep. Both tests held for 2 minutes.

Test passed.

Comments: