

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200 FAX(816)969-1201

Inspection Summary

Permit #: PRCOM20182193
Address: 450 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mark Harding	Failed	Wednesday, November 14, 2018

Corrective Action Required:
1 Misc

- EXTERIOR WALL SHEATHING INSPECTION:
PLANS DO NOT STATE WHERE THE SHEAR WALLS ARE LOCATED.
NAIL PATTERN IS PER SECTION 2304.9.1 (6x12.)

Comments: