

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200 FAX(816)969-1201

Inspection Summary

Permit #: PRSITE20180252
Address: 1600 SE HAMBLER RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer - Mandrel		Passed	Wednesday, November 14, 2018

Informational:
1 Misc The crew pulled the 8" in mandrel through the line with no deflection.
I verified that the mandrel was in compliance.

Comments: