

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20181713
Address: 3348 SW JESSIE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mike Copeland	Failed	Thursday, November 15, 2018

Corrective Action Required:

1	Misc	-REPLACE/SISTER OVERNOTCH STUDS IN GARAGE ANCHOR BOLT LOCATIONS -FIRBLOCKING IN BASEMENT FINISH REQUIRED TO BE 3/4" PLYWOOD. USED 3/8ths IN AREAS.
---	------	---

Comments: