



PLANS REVIEW CONDITIONS

Permit No: PRCOM20172500 Date: November 19, 2018
Project Title: MERIDIAN AT VIEW HIGH - CLUBHOUSE Applicant:
Location: 201 NW KESSLER DR, LEES SUMMIT, MO 64081 RANGER FIRE INC
1000 S MAIN ST STE 150
GRAPEVINE, TX 76051
Type of Work: Primary: (817) 410-9070
Occupancy Group: A-3
Description: NEW CLUBHOUSE WITH DOG GROOMING AND GYM
FOUNDATION PERMIT - PRCOM20180696
Construction Type: Type VB (Unprotected)
Map Page: 194F

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Joe Dir

Rejected

1. Dry System Inspectors test valves

ACTION REQUIRED: Plans need to indicate the location of the dry system inspectors test valves on all buildings.

2. Post Indicator Valves

ACTION REQUIRED: Take the PIVs out of the plans, PIVs are not required for these buildings.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.