

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20182476
Address: 2321 NE LAKE BREEZE LN, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Residential	Khanh Nguyen	Passed	Monday, November 19, 2018

Informational:
1 MAKE SURE THAT THE POWER SUPPLY FOR THE LOW VOLTAGE POOL LIGHT, IF INSTALLED, SHALL BE UL LISTED FOR SWIMMING POOL

Comments: