

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20181745
Address: 1713 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Jason McRoy	Failed	Tuesday, November 20, 2018

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">• no self closing hinges at garage entry door• Add ledger locks at west side of deck.• Smoke in master bedroom not working correctly, sounds partially in room but doesn't sound through house. Won't test completely.• Seal gas line penetration outside• Sod• Discharge sump 36" from structure |
|---|------|--|

Comments: