

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20181829
Address: 1325 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DEI-Sidewalk Inspection	Ronald Paynter	Partial	Tuesday, November 20, 2018

Corrective Action Required:

1	Misc	Forms are out spec tolerance for cross slope, aggregate still needs to be compacted. We informed the flat workers. They will make corrections before pouring concrete
---	------	---

Comments: