

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20180476
Address: 1345 NE BRANDYWINE RD, LEES SUMMIT, MO 64064
Inspected On: Tuesday, November 27, 2018
Inspected By: Khanh Nguyen
Expiration Date: 11/29/2018 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Temporary C of O	Tuesday, November 27, 2018

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | -COMPLETE DECK
**INSTALL HANDRAIL NO WIDER THAN 3.5" |
| | | -SEWER TRACE BOX AND WIRE SHALL BE ACCESSIBLE AT GRADE
LEVEL |
| | | -THE METER TOP MUST FLUSH WITH FINAL GRADE. MAINTAIN
METER-LID DISTANCE OF 14"-18" |
| | | -DO NOT BURY DECK CEDAR POSTS (SOUTH POSTS) |

