

Inspection Summary

Permit #: PRSUBD20181667, Development - Subdivision
Whispering Woods
Address: 2601 SW PRYOR RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer - Air Test	John DiMauro	Partial	Tuesday, November 27, 2018

Informational

1 John DiMauro 11/27/2018 10:39 AM

Air pressure test for the sanitary sewer line G.

The test for the Line segment from station 6+27.21 to 7+77.05 is 149.84 LF.

Start PSI: 4

End PSI: 4

Test Time: 34 min 10 sec

Test passed

The test for the Line segment from station 2+27.21 to 6+27.21 is 400 LF.

Start PSI: 4

End PSI: 4

Test Time: 91 min 12 sec

Test passed

DEI-Sanitary Sewer - Vacuum	John DiMauro	Partial	Tuesday, November 27, 2018
-----------------------------	--------------	---------	----------------------------------

Informational

1 John DiMauro 11/27/2018 11:35 AM

The crew vacuum tested MH E-1

The gauge dropped from 10 to 9.5 during the 2.5 min test. Test Passed.

Vacuum test for MH G-3

The gauge dropped below the allowed limit in the 2.5 minute test.

Test Failed

Comments:
