

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20180728
Address: 1845 SW BLACKSTONE CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Jason McRoy	Failed	Wednesday, November 28, 2018

Corrective Action Required:

2	Misc	<ul style="list-style-type: none">• hand railing required at garage entry door• Smoke in master will not test correctly doesn't respond to whole house system• Add 4 double joist hangers at deck add 1 strap Nile joist hanger• Add ledger locks or lags at ledger board connection to house per code• Gfci in guest baths on first fl are wired incorrectly cannot trip and reset in front bath it is connected to basement bath• Final grade• Sod
---	------	--

Comments: