

Inspection Summary

Permit #: PRSUBD20181667, Development - Subdivision
Whispering Woods
Address: 2601 SW PRYOR RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer - Vacuum	John DiMauro	Partial	Wednesday, November 28, 2018

Informational

1 John DiMauro 11/28/2018 10:08 AM

The crew vacuum tested MH B-1
The gauge held at 10 with no drop during the 2.5 min test. Test Passed.

DEI-Sanitary Sewer - Air Test	John DiMauro	Partial	Wednesday, November 28, 2018
-------------------------------	--------------	---------	------------------------------------

Informational

1 John DiMauro 11/28/2018 9:11 AM

Air pressure test for the sanitary sewer line G.

The test for the Line segment from station 0+00 to 2+27.21 is 227.21 LF.

Start PSI: 4

End PSI: 4

Test Time: 51 min 42 sec

Test passed

Comments:

