

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20182264  
Address: 1833 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Jason McRoy	Failed	Wednesday, November 28, 2018

Corrective Action Required:

1 Misc

Corrective Action Required:

3 Misc

- add anchor at sill plate east side of garage at splice
- Jacuzzi tub not installed at master bed
- Add stud shoes at master bath vanity
- Electric panel enclosure is not grounded
- \* Gas line only holding 5 lbs of pressure

\* OK TO INSULATE

**Comments:**