

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20181747
Address: 2533 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mark Harding	Failed	Thursday, November 29, 2018

Corrective Action Required:

1	Misc	-Flue clearance at 2nd floor flue chase. Clearance to 2x4 needs to be 1" And to 3/4" smart trim. Ok to insulate
---	------	---

Comments: