

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20180411
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DEI-Water Line - Construction Inspection	John DiMauro	Partial	Tuesday, December 04, 2018

Informational:

1 Misc

The Redford Construction crew is installing the 12" C900 water line along SW Georgetown east of SW Stoney creek Dr. They currently have approximately 28'ft installed.

I will return for further inspection.

Comments: