

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20181463
Address: 4712 NE POCONO CIR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Steve Conrick	Failed	Wednesday, December 05, 2018

Corrective Action Required:

1	Misc	Replace silt fence at back of lot to prevent silt leaving site.
---	------	---

Corrective Action Required:

2	Misc	Side yard needs to be lower than or equal to elevation with 4716 property to the north so that water drains as per the submitted plot plan.
---	------	---

Comments: