

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20181505
Address: 1040 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Wednesday, December 05, 2018

Corrective Action Required:

1	Misc	-BLANK OFF OPENING AT PANEL -EXTEND THE SEWER VENT 2 FT ABOVE OR MIN. 10 FT AWAY FROM OPENABLE WINDOW -DRIVE THE GROUND ROD INTO GROUND NO MORE THAN 45 DEGRESS FROM VERTICAL; OR BURY IN TRENCH MIN. 30" DOWN
---	------	--

Comments: