

Inspection Summary

Permit #: PRSUBD20162865, Development - Subdivision

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Water Line - Fire Hydrant	John Jackson	Partial	Wednesday, December 05, 2018

Informational

1 Hydrants installed @ Sta 1+57.50 & 5+85.47. John Jackson 12/05/2018 9:25 AM

DEI-Water Line - Construction Inspection	John Jackson	Partial	Wednesday, December 05, 2018
---	--------------	---------	------------------------------------

Informational

1 Contractor installed 8" C-900 Class 200 PVC from sta 1+25 to Sta 6+00 on line 9. John Jackson 12/05/2018 9:29 AM

DEI-Grading/Excavation/Fill Inspection	John Jackson	Partial	Wednesday, December 05, 2018
---	--------------	---------	------------------------------------

Informational

1 Contractor began grading streets. Temperature above 30 degrees. John Jackson 12/05/2018 9:49 AM

Comments: