

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20183473
Address: 424 NW MAIN ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - Residential	John Borns	Passed	Thursday, December 06, 2018

Comments: OK TO COVER WHEN READY WATER SERVICE INSTALLATION FROM TAP TO METER WELL SET TO ELEVATION TO BUILDING ENTRY.