

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20181337
Address: 2424 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mark Harding	Failed	Friday, December 07, 2018

Corrective Action Required:

1	Misc	-firestop heat chase in garage and flue chase vertical to horizontal. -seal penetrations at 1000 sq ft draft stops. Ok to insulate Recall when ready
---	------	---

Comments: