

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20181337  
Address: 2424 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mark Harding	Failed	Friday, December 07, 2018

Corrective Action Required:

1	Misc	-firestop heat chase in garage and flue chase vertical to horizontal. -seal penetrations at 1000 sq ft draft stops. Ok to insulate Recall when ready
---	------	---

**Comments:**