

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20181745
Address: 1713 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Jason McRoy	Failed	Monday, December 10, 2018

Corrective Action Required:

1	Misc	Smoke alarm in master bedroom only beeps when held. there is no audible alarm. Alarm does not respond to whole house alarm system
		Final grading
		Sod

Comments: