

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20180561  
Address: 1510 SE KINGSPPOINT DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DEI-Proof roll parking lot</b>	John DiMauro	Failed	Monday, December 10, 2018

Corrective Action Required:

1	Misc	The proof roll for the parking lot failed. There was significant rutting under the truck. I do not recommend pouring concrete on this parking lot subgrade at this time.
---	------	--

**Comments:**