

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20182457
Address: 2602 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mark Harding	Failed	Tuesday, December 11, 2018

Corrective Action Required:

1	Misc	-Provide plans on site at time of inspection. -install required erosion control at street. -joist hanger ceiling joist over entry at can light. -install straps at garage doors. -install stud or header over cut stud for hood. Exterior wall. - block hole in bottom plate north Side of 1st floor, missed cut for havc.
---	------	---

Comments: