CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20183262

Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Footing Inspection - Mike Copeland Partial Wednesday, December

Commercial 05, 2018

Partial Correction:

1 Misc UFFER GROUND: 1 OF 3 UFFER APPROVED NORTH ELEVATION

Partial Correction:

THE FOLLOWING EAST ELEVATION FROM A.B TO NORTH ELEV.; NORTH ELEVATION APPROVED;

AREAS ARE WEST ELEVATION FROM NORTH TO A.N LINE

APPROVED

Comments: