

Inspection Summary

Permit #: PRSUBD20162865, Development - Subdivision

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer - Mandrel	John Jackson	Partial	Tuesday, December 11, 2018

Informational

- 1 Mandrel test pass for the remaining proption of the sanitary sewer main and manholes. Mandrel C-8, C-7, C-6, & C-5 passed.

Comments: