

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20162865  
Address:

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DEI-Sanitary Sewer - Mandrel</b>	John Jackson	Passed	Tuesday, December 11, 2018

Informational:

1

Mandrel test pass for the remaining proption of the sanitary sewer main and manholes. Mandrel C-8, C-7, C-6, & C-5 passed.

**Comments:**