

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20162865  
Address:

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                     | Inspector:   | Outcome: | Date:                      |
|---------------------------------|--------------|----------|----------------------------|
| <b>DEI-Curb New/Replacement</b> | John Jackson | Passed   | Tuesday, November 20, 2018 |

Informational:  
1 Contractor installed approximately 60% of curb on newly constructed roads. All curbs were blanketed due to the forecasting of overnite freezing temperatures.

Informational:  
2 Contractor installed 60% of curbs on 11/16/18 Friday & blanketed curbs. Contractor continued installation of curbs Monday 11/19/18 & blanketed curbs as section 502.4.1 Porland cement concrete base pavement Cold Weather Concrete. John Jackson 11/20/2018 8:27 AM

**Comments:**