

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20162865
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DEI-Water Line - Construction Inspection	John Jackson	Partial	Wednesday, December 05, 2018

Informational:

1

Contractor secured installation of fire hydrants on line 9 and installed approximately 200' of 8" C-900 Class 200 PVC Water Main on Line 8 From 0+30 to 2+00. John Jackson 12/05/2018 4:01 PM

Comments: