

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20162865

Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DEI-Water Line - Construction Inspection	John Jackson	Partial	Monday, December 10, 2018

Informational:

1

Contractor installed approximately 500' of 8" C-900 Class 200 PVC water main on Line 6. Contractor has completed the initial installation of water mains on the project.

Comments: