

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20162865
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer - Vacuum	John Jackson	Passed	Wednesday, December 12, 2018

Informational:
1 Misc Contractor completed vacuum test on the off-site sanitary Manholes C-5 to C-10. Vacuum complete for all MH on project.

Comments: