

# Inspection Summary

Permit #: PRSUBD20162865, Development - Subdivision

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer - Air Test	John Jackson	Passed	Wednesday, December 12, 2018

Informational

1 Contractor completed all air test on off-site 8" sanitary main.

Informational

2 Contractor completed all air test on off-site 8" sanitary main.

DEI-Sanitary Sewer - Vacuum	John Jackson	Passed	Wednesday, December 12, 2018
-----------------------------	--------------	--------	------------------------------------

Informational

1 Contractor completed vacuum test on the off-site sanitary Manholes C-5 to C-10. Vacuum complete for all MH on project.

DEI-Water Line - Thrust Restraint	John Jackson	Passed	Wednesday, December 12, 2018
--------------------------------------	--------------	--------	------------------------------------

Informational

1 Contractor poured all backing blocks and straddle blocks on water main that were required as per project plans.

Comments:

