

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20183471
Address: 420 NW MAIN ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sewer Service Inspection - Residential	John Borns	Passed	Thursday, December 13, 2018

Comments: OK TO COVER WHEN READY SANITARY SEWER SERVICE INSTALLATION FROM BUILDING ENTRY TO CONNECTION AT STUB.