

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20162865  
Address:

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DEI-Water Line - Hydrostatic Test</b>	John Jackson	Passed	Thursday, December 13, 2018

Informational:

1	Misc	Hydrostatic test on water line 9, 8" PVC passed @ 11am (approximately 600' of water main). Hydrostatic test on water line 8, 8" PVC passed @ 1:15pm (approximately 240' of water main). Hydrostatic test on water Line 7, 8" PVC passed @ 3:45pm (approximately 150' of water main).
---	------	--

**Comments:**