

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20162865
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DEI-Water Line - Hydrostatic Test	John Jackson	Passed	Thursday, December 13, 2018

Informational:

1 Misc

Hydrostatic test on water line 9, 8" PVC passed @ 11am (approximately 600' of water main). Hydrostatic test on water line 8, 8" PVC passed @ 1:15pm (approximately 240' of water main). Hydrostatic test on water Line 7, 8" PVC passed @ 3:45pm (approximately 150' of water main).

Comments: