

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20183262  
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	John Borns	Partial	Tuesday, December 18, 2018

Partial Correction:

1	Misc	UFFER GROUND: 1 OF 3 UFFER APPROVED NORTH ELEVATION; UFFER AND REMAINDER PERIMETTER APPROVED TO POUR
---	------	--

Partial Correction:

2	THE FOLLOWING AREAS ARE APPROVED	a.7/a.r to FOOTINGS AT LEFT WING: EAST ELEVATION FROM A.B TO NORTH ELEV.; NORTH ELEVATION APPROVED; WEST ELEVATION FROM NORTH TO A.N LINE; ON A.1 FROM A.B TO A.Q; FROM A.1/A.Q CW TO A.AX/A.6 WITH UFER GROUND JUMPER; A.7/A.AX CW ATO A.7/A.AG; A.7/A.R TO A.7/A.E;
---	----------------------------------	---

Partial Correction:

3	Misc	<b>OK TO POUR WHEN READY TWO ELEVATOR PIT SLABS</b>
---	------	---

**Comments:**